

ERW Steel Tubes (For Cement Lined Pipes)

SPAN TS 21827 : PART 2 : 2013/BS 3601

Outside Diameter	Minimum Wall Thickness	Outside Diameter		Calculated Weight Plain
		Maximum	Minimum	
mm	mm	mm	mm	kg/m
114.3	3.6	115.4	113.2	10.35
139.7	3.6	141.1	138.3	12.73
168.3	3.6	170.0	166.6	15.41
193.7	4.0	195.2	192.2	19.63
219.1	4.0	221.3	216.9	22.26
244.5	4.0	246.9	242.1	24.89
273.0	4.0	275.7	270.3	27.84